

# Certified Elements

**DESAL<sup>®</sup>**  
MEMBRANE PRODUCTS

## NSF 61 Certified Drinking Water RO and NF Elements

The National Sanitation Foundation (NSF) provides conformity assessment services in the area of public health for the food preparation and plumbing water industries. NSF is an organization accredited by the American National Standard Institute (ANSI) to certify products against several NSF/ANSI Standards, including NSF Standard 61. NSF/ANSI Standard 61 is a testing protocol that assures customers and regulators that products do not contribute to unsafe levels of contaminants in drinking water.

AG, AK and HL certified elements are selected when incomparable confidence is requested from drinking water system components.

AG, AK and HL certified elements feature a fiberglass outer wrap and standard feed spacers.

**Table 1: Element Specification**

Membrane	Thin-Film Membrane (TFM*)
----------	---------------------------

### AG Series - RO High Rejection Elements

Model	Average permeate flow gpd (m <sup>3</sup> /day) <sup>1,2</sup>	Average NaCl rejection <sup>1,2</sup>	Minimum NaCl rejection <sup>1,2</sup>
AG4040FM CERT	2,200 (8.3)	99.5 %	99.0 %
AG8040F CERT	9,200 (34.8)	99.5 %	99.0 %
AG8040F 400 CERT	10,500 (39.8)	99.5 %	99.0 %

<sup>1</sup> Average salt rejection after 24 hours operation. Individual flow rate may vary +25%/-15%.

<sup>2</sup> Testing conditions: 2,000ppm NaCl solution at 225psi (1,551kPa) operating pressure, 77 °F, pH 7.5 and 15% recovery.

### AK Series - RO Low Energy Elements

Model	Average permeate flow gpd (m <sup>3</sup> /day) <sup>1,2</sup>	Average NaCl rejection <sup>1,2</sup>	Minimum NaCl rejection <sup>1,2</sup>
AK4040FM CERT	2,200 (8.3)	99.0 %	98.0 %
AK8040F 400 CERT	10,500 (39.8)	99.0 %	98.0 %

<sup>1</sup> Average salt rejection after 24 hours operation. Individual flow rate may vary +25%/-15%.

<sup>2</sup> Testing conditions: 500ppm NaCl solution at 115 psi (790kPa) operating pressure, 77 °F, pH 7.5 and 15% recovery.


### HL Series - Nanofiltration Elements

Model	Average permeate flow gpd (m <sup>3</sup> /day) <sup>1,2</sup>	Average MgSO <sub>4</sub> rejection <sup>1,2</sup>
HL4040FM CERT	2,400 (9.1)	98.0 % <sup>1,2</sup>

<sup>1</sup> Average salt rejection after 24 hours operation. Individual flow rate may vary +25%/-15%.

<sup>2</sup> Testing conditions: 2,000 ppmMgSO<sub>4</sub> solution at 110psi (760kPa) operating pressure, 77 °F, pH 7.5 and 15% recovery.

Model	Active area ft <sup>2</sup> (m <sup>2</sup> )	Outer wrap	Part number
AG4040FM CERT	85 (7.9)	Fiberglass	1231652
AG8040F CERT	350 (32.5)	Fiberglass	1231653
AG8040F 400 CERT	400 (37.2)	Fiberglass	1231654
AK4040FM CERT	85 (7.9)	Fiberglass	1231655
AK8040F 400 CERT	400 (37.2)	Fiberglass	1231656
HL4040FM CERT	89 (8.2)	Fiberglass	1233081



**Figure 1: Element Dimensions Diagram – Female**


a product of  
**ecomagination<sup>™</sup>**



Find a contact near you by visiting [www.ge.com/water](http://www.ge.com/water) and clicking on "Contact Us".

\* Trademark of General Electric Company; may be registered in one or more countries.

©2009, General Electric Company. All rights reserved.



**Figure 2: Element Dimensions Diagram – Male**

**Table 2: Dimensions and Weight**

Model <sup>1</sup>	Dimensions, inches (cm)			Boxed Weight lbs (kg)
	A	B <sup>2</sup>	C <sup>3</sup>	
AG4040FM CERT	40.0 (101.6)	0.75 (1.90) OD	3.9 (9.9)	8 (3.5)
AG8040F CERT	40.0 (101.6)	1.125 (2.86)	7.9 (20.1)	32 (14.5)
AG8040F 400 CERT	40.0 (101.6)	1.125 (2.86)	7.9 (20.1)	32 (14.5)
AK4040FM CERT	40.0 (101.6)	0.75 (1.90) OD	3.9 (9.9)	8 (3.5)
AK8040F 400 CERT	40.0 (101.6)	1.125 (2.86)	7.9 (20.1)	32 (14.5)
HL4040FM CERT	40.0 (101.6)	0.75 (1.90) OD	3.9 (9.9)	8 (3.5)

<sup>1</sup>These elements are bagged dried before shipping.

<sup>2</sup>Internal diameter unless specified OD (outside diameter).

<sup>3</sup>The element diameter (dimension C) is designed for optimum performance in GE Water & Process Technologies pressure vessels. Other pressure vessel dimension and tolerance may result in excessive bypass and loss of capacity.

**Table 3: Operating and CIP parameters**

Typical Operating Pressure	AG Series: 200 psi (1,379 kPa) AK Series: 100 psi (689 kPa) HL Series: 70-300 psi (483-2,069 kPa)
Typical Operating Flux	10-20GFD (15-35LMH)
Maximum Operating Pressure	AG Series: 600 psi (4,137 kPa), AK Series: 400 psi (3,758 kPa) HL Series: 600 psi (4,137 kPa)
Maximum Temperature	All: Continuous operation: 122°F (50°C) AG-AK Series Clean-In-Place (CIP): 122°F (50°C) HL Series Clean-In-Place (CIP): 104°F (40°C)
pH Range	AG-AK Series: Optimum rejection pH: 7.0-7.5 Continuous operation: 4.0-11.0 Clean-In-Place (CIP): 2.0-11.5 HL Series: Optimum rejection pH: 6.0-7.0 Continuous operation: 3.0-9.0 Clean-In-Place (CIP): 2.0-10.5
Maximum Pressure Drop	Over an element: 12psi (83kPa) Per housing: 50psi (345kPa)
Chlorine Tolerance	1,000+ ppm-hours, dechlorination recommended
Feedwater	NTU < 1 SDI < 5